

EEGA - Energy Efficiency Gap Analysis

Best Store Group



Commercial/Institutional - Food retail

Prepared for:

General Manager
Best Store Group
Retail Way
Swindon
United Kingdom

Prepared by:

Best.Energy
Energy Services Team
United Kingdom
E-mail: save@best.energy



Executive summary

This report was prepared by the Best.Energy Energy Saving Team (EST). These preliminary findings and recommendations are based on a desk-top study using the information provided. The objective of the Energy Efficiency Gap Analysis is to quantify energy use and carbon emissions arising from the site's energy systems and to compare these against benchmarks of similar sites with the same/similar activities to quantify the potential for energy savings and carbon reductions. The costs and benefits of actual energy efficiency actions have been used to quantify the savings. It is important to realise this Report is only an indication of possible savings – some actions may not be possible at your site. Where this Report indicates opportunities exist, the next step is a physical site survey to gather more detailed information for the generation of a Best.Energy ESOR: Energy Savings Opportunity Report.

Target

	Fuel consumption kWh	Fuel cost £	GHG emission tCO ₂
Base case	2,081,154	185,838	1,408
Proposed case	1,079,153	107,494	258
Savings	1,002,002	78,344	1,150
%	48.1%	42.2%	81.7%

IMPORTANT NOTICE

Whilst reasonable steps have been taken to ensure that the information contained within this Savings Report is correct, you should be aware that the information contained within it may be incomplete, inaccurate or may have become out of date. Accordingly, Best.Energy, its agents, contractors and sub-contractors make no warranties or representations of any kind as to the content of this Report or its accuracy and, to the maximum extent permitted by law, accept no liability whatsoever for the same including without limit, for direct, indirect or consequential loss, business interruption, loss of profits, production, contracts, goodwill or anticipated savings. Any person making use of this Report does so at their own risk.

CONFIDENTIALITY

As part of energy consulting work Best.Energy may have access to client information which may be of a confidential or sensitive nature. Such information is treated in the strictest confidence and will not be communicated or otherwise transmitted to a third party unless expressly authorised to do so by the Client.

COPYRIGHT

All rights reserved. The information contained in this document is confidential. It may also be proprietary to the client. Without the prior written approval of Best.Energy, no part of this document may be reproduced or transmitted in any form by any means, including, but not limited to electronic, mechanical, photocopying or recording or stored in any retrieval system of whatever nature, although copyright is waived to the extent that they may be copied for use by the managers and employees of the client. Use of any copyright notice does not imply unrestricted public access to any part of this document.

Location | Climate data

Location




Legend

- Facility location
- Climate data location

	Unit	Climate data location	Facility location
Name		United Kingdom - Fairford RAF	United Kingdom - England - Swindon
Latitude	°N	51.7	51.6
Longitude	°E	-1.8	-1.8
Climate zone		4A - Mixed - Humid	4A - Mixed - Humid
Elevation	m	87	105


Climate data



Heating design temperature	-4.0								
Cooling design temperature	24.9								
Earth temperature amplitude	15.0								
Month	Air temperature	Relative humidity	Precipitation	Daily solar radiation - horizontal	Atmospheric pressure	Wind speed	Earth temperature	Heating degree-days	Cooling degree-days
	°C	%	mm	kWh/m ² /d	kPa	m/s	°C	°C-d	°C-d
January	3.9	81.3%	73.16	0.77	100.1	4.4	3.0	437	0
February	3.4	75.3%	52.08	1.39	100.2	4.4	3.2	409	0
March	5.7	73.9%	52.70	2.34	100.1	4.4	5.5	381	0
April	8.0	74.3%	58.20	3.59	99.9	3.7	8.0	300	0
May	11.2	75.9%	57.66	4.57	100.1	3.7	11.6	211	37
June	14.4	76.2%	60.90	4.84	100.2	3.4	14.7	108	132
July	17.5	71.2%	59.52	4.80	100.2	3.3	17.2	16	233
August	16.2	71.7%	62.00	4.23	100.1	3.2	17.0	56	192
September	14.1	76.6%	59.70	2.86	100.2	3.2	13.9	117	123
October	11.1	82.3%	79.98	1.73	99.9	3.7	10.1	214	34
November	6.7	84.1%	76.20	0.96	99.9	3.6	6.0	339	0
December	5.7	83.9%	77.19	0.60	100.0	4.2	3.7	381	0
Annual	9.9	77.2%	769.29	2.73	100.1	3.8	9.5	2,969	751

Benchmark


Fuel consumption



Facility size	4,000	m ²
Benchmark	660	kWh/m ²
Minimum - average	194	kWh/m ²
Maximum - average	1,439	kWh/m ²
Base case	520	kWh/m ²
Reference year		
Set target	Target	
Year		
Target	-48.1%	
Proposed case	270	kWh/m ²
Facility - Plan		
Fuel consumption	Annual	
Base case	2,081,154	kWh
Proposed case	1,079,153	kWh
Fuel saved	1,002,002	kWh


Energy savings | Fuel summary

Energy savings



Fuel consumption	Heating kWh	Cooling kWh	Electricity kWh	Total kWh
Base case	354,078	805,913	921,163	2,081,154
Proposed case	6,702	343,660	728,790	1,079,153
Fuel saved	347,376	462,253	192,373	1,002,002
Fuel saved - percent	98.1%	57.4%	20.9%	48.1%

Fuel summary




Fuel type	Fuel Unit	Base case Fuel consumption	Proposed case Fuel consumption	Savings Fuel saved
Natural gas	m ³	37,515	710	36,805
Electricity	kWh	1,727,076	1,072,450	654,626


Fuel type	Fuel rate	Base case Fuel cost	Proposed case Fuel cost	Savings Savings
Natural gas	0.35 £/m ³	£ 13,130	£ 249	£ 12,882
Electricity	0.10 £/kWh	£ 172,708	£ 107,245	£ 65,463
Total		£ 185,838	£ 107,494	£ 78,344

GHG emission

GHG emission



GHG equivalence



GHG emission		
Base case	1,408.3	tCO ₂
Proposed case	258.2	tCO ₂
Gross annual GHG emission reduction	1,150.1	tCO ₂